

NPDES Permit No. IL0045381

Notice No. KKD:25020501

Public Notice Beginning Date: March 12, 2025

Public Notice Ending Date: April 11, 2025

National Pollutant Discharge Elimination System (NPDES)  
Permit Program

PUBLIC NOTICE/FACT SHEET  
of  
Draft Reissued NPDES Permit to Discharge into Waters of the State

Public Notice/Fact Sheet Issued By:

Illinois EPA  
Division of Water Pollution Control  
Permit Section  
2520 West Iles Avenue  
Post Office Box 19276  
Springfield, Illinois 62794-9276  
217/782-0610

Name and Address of Discharger:

Prairie Path Water Company  
500 W. Monroe Street, Suite 3600  
Chicago, Illinois 60661

Name and Address of Facility:

Camelot Utilities STP  
Queens Court and Pellinore Road  
Joliet, Illinois 60431  
(Will County)

The Illinois Environmental Protection Agency (IEPA) has made a tentative determination to issue a NPDES Permit to discharge into the waters of the state and has prepared a draft Permit and associated fact sheet for the above named discharger. The Public Notice period will begin and end on the dates indicated in the heading of this Public Notice/Fact Sheet. All comments on the draft Permit and requests for hearing must be received by the IEPA by U.S. Mail, carrier mail or hand delivered by the Public Notice Ending Date. Interested persons are invited to submit written comments on the draft Permit to the IEPA at the above address. Commentors shall provide his or her name and address and the nature of the issues proposed to be raised and the evidence proposed to be presented with regards to those issues. Commentors may include a request for public hearing. Persons submitting comments and/or requests for public hearing shall also send a copy of such comments or requests to the Permit applicant. The NPDES Permit and notice numbers must appear on each comment page.

The application, engineer's review notes including load limit calculations, Public Notice/Fact Sheet, draft Permit, comments received, and other documents are available for inspection and may be copied at the IEPA between 9:30 a.m. and 3:30 p.m. Monday through Friday when scheduled by the interested person.

If written comments or requests indicate a significant degree of public interest in the draft Permit, the permitting authority may, at its discretion, hold a public hearing. Public notice will be given 45 days before any public hearing. Response to comments will be provided when the final Permit is issued. For further information, please call Kaushal Desai at 217/782-0610.

The following water quality and effluent standards and limitations were applied to the discharge:

Title 35: Environmental Protection, Subtitle C: Water Pollution, Chapter I: Pollution Control Board and the Clean Water Act were applied in determining the applicable standards, limitations and conditions contained in the draft Permit.

The applicant is engaged in treating domestic wastewater for the Camelot Subdivision.

The length of the Permit is approximately 5 years.

The main discharge number is 001. The seven day once in ten year low flow (7Q10) of the receiving stream, DuPage River, is 93 cfs.

The design average flow (DAF) for the facility is 0.1 million gallons per day (MGD) and the design maximum flow (DMF) for the facility is 0.25 MGD. Treatment consists of screening, activated sludge, sedimentation, disinfection and dechlorination. Sludge is aerobically digested and sent to Twin Lakes Utilities STP in Crown Point, Indiana for final disposal.

This Reissued Permit does not increase the facility's DAF, DMF, concentration limits, and/or load limits.


Pursuant to the waiver provisions authorized by 40 CFR § 123.24, this draft permit is within the class, type, and size for which the Regional Administrator, Region V, has waived his right to review, object, or comment on this draft permit action.

Application is made for the existing discharge(s) which is located in Will County, Illinois. The following information identifies the discharge point, receiving stream and stream classifications:

| <u>Discharge<br/>Number</u> | <u>Receiving Stream</u> | <u>Latitude</u>   | <u>Longitude</u> | <u>Stream<br/>Classification</u> | <u>Integrity<br/>Rating</u> |
|-----------------------------|-------------------------|-------------------|------------------|----------------------------------|-----------------------------|
| 001                         | DuPage River            | 48° 28' 20" North | 88° 12' 36" West | General Use                      | C                           |

To assist you further in identifying the location of the discharge(s) please see the map below.

The stream segment receiving the discharge from outfall(s) 001, waterbody segment IL\_GB-01, is on the 2020/2022 Illinois Integrated Water Quality Report and Section 303(d) and impaired for fish consumption use with potential causes given as mercury and polychlorinated biphenyls.



The discharge(s) from the facility is (are) proposed to be monitored and limited at all times as follows:

Discharge Number(s) and Name(s): 001 STP Outfall

Load limits computed based on a design average flow (DAF) of 0.1 MGD (design maximum flow (DMF) of 0.25 MGD).

The effluent of the above discharge(s) shall be monitored and limited at all times as follows:

| <u>Parameter</u>         | <u>LOAD LIMITS lbs/day</u>                     |                       |                      | <u>CONCENTRATION</u>   |                       |                      | <u>Regulation</u>                |
|--------------------------|--|-----------------------|----------------------|------------------------|-----------------------|----------------------|----------------------------------|
|                          | <u>DAF (DMF)*</u>                              |                       |                      | <u>LIMITS mg/L</u>     |                       |                      |                                  |
|                          | <u>Monthly Average</u>                         | <u>Weekly Average</u> | <u>Daily Maximum</u> | <u>Monthly Average</u> | <u>Weekly Average</u> | <u>Daily Maximum</u> |                                  |
| CBOD <sub>5</sub> **     | 21 (52)  | 33 (83)               |                      | 25                     | 40                    |                      | 35 IAC 304.120<br>40 CFR 133.102 |
| Suspended Solids**       | 25 (63)  | 38 (94)               |                      | 30                     | 45                    |                      | 35 IAC 304.120<br>40 CFR 133.102 |
| pH                       | Shall be in the range of 6 to 9 Standard Units |                       |                      |                        |                       |                      | 35 IAC 304.125                   |
| Fecal Coliform           | Daily Maximum shall not exceed 400 per 100 mL  |                       |                      |                        |                       |                      | 35 IAC 309.146                   |
| Chlorine Residual        |  |                       |                      |                        |                       | 0.05                 | 35 IAC 302.208                   |
| Ammonia Nitrogen: (as N) |  |                       |                      |                        |                       |                      | 35 IAC 355 and<br>35 IAC 302     |
| March-May/Sept.-Oct.     | 1.3 (3.1)                                      | 3.2 (7.9)             | 3.3 (8.1)            | 1.5                    | 3.8                   | 3.9                  |                                  |
| June-August              | 0.83 (2.1)                                     | 2.2 (5.4)             | 5.8 (14)             | 1.0                    | 2.6                   | 6.9                  |                                  |
| Nov.-Feb.                | 3.8 (9.4)                                      |                       | 8.4 (21)             | 4.5                    |                       | 10.1                 |                                  |
| Total Phosphorous (as P) |  |                       | Monitor Only         |                        |                       | Monitor Only         | 35 IAC 309.146                   |

\*Load Limits are calculated by using the formula:  $8.34 \times (\text{Design Average and/or Maximum Flow in MGD}) \times (\text{Applicable Concentration in mg/L})$

\*\*BOD<sub>5</sub> and Suspended Solids (85% removal required): In accordance with 40 CFR 133, the 30-day average percent removal shall not be less than 85 percent.

This draft Permit also contains the following requirements as special conditions:

1. Reopening of this Permit to include different final effluent limitations.
2. Operation of the facility by or under the supervision of a certified operator.
3. Submission of the operational data in a specified form and at a required frequency at any time during the effective term of this Permit.
4. More frequent monitoring requirement without Public Notice.
5. Prohibition against causing or contributing to violations of water quality standards.
6. Recording the monitoring results on Discharge Monitoring Report Forms using one such form for each outfall each month and submitting the forms to IEPA each month.
7. The provisions of 40 CFR Section 122.41(m) & (n) are incorporated herein by reference.
8. Effluent sampling point location.
9. Reopening of this Permit to include revised effluent limitations based on a Total Maximum Daily Load (TMDL) or other water quality study.
10. Submission of semi annual reports indicating the quantities of sludge generated and disposed.
11. Mixing zone requirements

NPDES Permit No. IL0045381  
Illinois Environmental Protection Agency  
Division of Water Pollution Control  
2520 West Iles Avenue  
Post Office Box 19276  
Springfield, Illinois 62794-9276

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM  
Reissued (NPDES) Permit

Expiration Date:

Issue Date:  
Effective Date:

Name and Address of Permittee:

Prairie Path Water Company  
500 W. Monroe Street, Suite 3600  
Chicago, Illinois 60661

Facility Name and Address:

Camelot Utilities STP  
Queens Court and Pellinore Road  
Joliet, Illinois 60431  
(Will County)

Receiving Waters: DuPage River

In compliance with the provisions of the Illinois Environmental Protection Act, Title 35 of the Ill. Adm. Code, Subtitle C, Chapter I, and the Clean Water Act (CWA), the above-named Permittee is hereby authorized to discharge at the above location to the above-named receiving stream in accordance with the Effluent Limitations, Monitoring, and Reporting requirements; Special Conditions and Attachment H Standard Conditions attached herein.

Permittee is not authorized to discharge after the above expiration date. In order to receive authorization to discharge beyond the expiration date, the Permittee shall submit the proper application as required by the Illinois Environmental Protection Agency (IEPA) not later than 180 days prior to the expiration date.

Brant D. Fleming, P.E.  
Manager, Municipal Unit, Permit Section  
Division of Water Pollution Control

BDF:KKD:25020501

NPDES Permit No. IL0045381  
Effluent Limitations, Monitoring, and Reporting  
 FINAL

Discharge Number(s) and Name(s): 001 STP Outfall

Load limits computed based on a design average flow (DAF) of 0.1 MGD (design maximum flow (DMF) of 0.25 MGD).

From the effective date of this Permit until the expiration date, the effluent of the above discharge(s) shall be monitored and limited at all times as follows:

| <u>Parameter</u>         | <u>LOAD LIMITS lbs/day</u>                     |                       |                      | <u>CONCENTRATION</u>   |                       |                      | <u>Sample Frequency</u> | <u>Sample Type</u> |
|--------------------------|--|-----------------------|----------------------|------------------------|-----------------------|----------------------|-------------------------|--------------------|
|                          | <u>DAF (DMF)*</u>                              |                       |                      | <u>LIMITS mg/L</u>     |                       |                      |                         |                    |
|                          | <u>Monthly Average</u>                         | <u>Weekly Average</u> | <u>Daily Maximum</u> | <u>Monthly Average</u> | <u>Weekly Average</u> | <u>Daily Maximum</u> |                         |                    |
| Flow (MGD)               |  |                       |                      |                        |                       |                      | Continuous              |                    |
| CBOD <sub>5</sub> **,**  | 21 (52)  | 33 (83)               |                      | 25                     | 40                    |                      | 1 Day/Month             | Composite          |
| Suspended Solids***      | 25 (63)  | 38 (94)               |                      | 30                     | 45                    |                      | 1 Day/Month             | Composite          |
| pH                       | Shall be in the range of 6 to 9 Standard Units |                       |                      |                        |                       |                      | 1 Day/Month             | Grab               |
| Fecal Coliform           | Daily Maximum shall not exceed 400 per 100 mL  |                       |                      |                        |                       |                      | 1 Day/Month             | Grab               |
| Chlorine Residual        |  |                       |                      |                        |                       | 0.05                 | 1 Day/Month             | Grab               |
| Ammonia Nitrogen: As (N) |  |                       |                      |                        |                       |                      |                         |                    |
| March-May/Sept.-Oct.     | 1.3 (3.1)                                      | 3.2 (7.9)             | 3.3 (8.1)            | 1.5                    | 3.8                   | 3.9                  | 1 Day/Month             | Composite          |
| June-August              | 0.83 (2.1)                                     | 2.2 (5.4)             | 5.8 (14)             | 1.0                    | 2.6                   | 6.9                  | 1 Day/Month             | Composite          |
| Nov.-Feb.                | 3.8 (9.4)                                      |                       | 8.4 (21)             | 4.5                    |                       | 10.1                 | 1 Day/Month             | Composite          |
| Total Phosphorous (as P) |  |                       | Monitor only         |                        |                       | Monitor only         | 1 Day/Month             | Grab               |

\*Load limits based on design maximum flow shall apply only when flow exceeds design average flow.

\*\*Carbonaceous BOD<sub>5</sub> (CBOD<sub>5</sub>) testing shall be in accordance with 40 CFR 136

\*\*\*BOD<sub>5</sub> and Suspended Solids (85% removal required): In accordance with 40 CFR 133, the 30-day average percent removal shall not be less than 85 percent. The percent removal need not be reported to the IEPA on DMRs but influent and effluent data must be available, as required elsewhere in this Permit, for IEPA inspection and review. For measuring compliance with this requirement, 5 mg/L shall be added to the effluent CBOD<sub>5</sub> concentration to determine the effluent BOD<sub>5</sub> concentration. Percent removal is a percentage expression of the removal efficiency across a treatment plant for a given pollutant parameter, as determined from the 30-day average values of the raw wastewater influent concentrations to the facility and the 30-day average values of the effluent pollutant concentrations for a given time period.

Flow shall be reported on the Discharge Monitoring Report (DMR) as monthly average and daily maximum.

pH shall be reported on the DMR as minimum and maximum value.

Dissolved oxygen shall be reported on the DMR as a minimum value.

Fecal Coliform shall be reported on the DMR as a daily maximum value.

Chlorine Residual shall be reported on the DMR as daily maximum value.

Total Phosphorus shall be reported on the DMR as a daily maximum value.

NPDES Permit No. IL0045381

Influent Monitoring, and Reporting

The influent to the plant shall be monitored as follows:

| <u>Parameter</u> | <u>Sample Frequency</u> | <u>Sample Type</u> |
|------------------|-------------------------|--------------------|
| Flow (MGD)       | Continuous              |                    |
| BOD <sub>5</sub> | 1 Day/Month             | Composite          |
| Suspended Solids | 1 Day/Month             | Composite          |

Influent samples shall be taken at a point representative of the influent.

Flow (MGD) shall be reported on the Discharge Monitoring Report (DMR) as monthly average and daily maximum.

BOD<sub>5</sub> and Suspended Solids influent data shall be reported on the DMR as a monthly average concentration.

Special Conditions

SPECIAL CONDITION 1. This Permit may be modified to include different final effluent limitations or requirements which are consistent with applicable laws and regulations. The IEPA will public notice the permit modification.

SPECIAL CONDITION 2. The use or operation of this facility shall be by or under the supervision of a Certified Class 2 operator.

SPECIAL CONDITION 3. The IEPA may request in writing submittal of operational information in a specified form and at a required frequency at any time during the effective period of this Permit.

SPECIAL CONDITION 4. The IEPA may request more frequent monitoring by permit modification pursuant to 40 CFR § 122.63 and Without Public Notice.

SPECIAL CONDITION 5. The effluent, alone or in combination with other sources, shall not cause a violation of any applicable water quality standard outlined in 35 Ill. Adm. Code 302 and 303.

SPECIAL CONDITION 6. The Permittee shall record monitoring results on Discharge Monitoring Report (DMR) electronic forms using one such form for each outfall each month.

In the event that an outfall does not discharge during a monthly reporting period, the DMR Form shall be submitted with no discharge indicated.

The Permittee is required to submit electronic DMRs (NetDMRs) instead of mailing paper DMRs to the IEPA unless a waiver has been granted by the Agency. More information, including registration information for the NetDMR program, can be obtained on the IEPA website, <https://epa.illinois.gov/topics/water-quality/surface-water/netdmr.html>.

The completed Discharge Monitoring Report forms shall be submitted to IEPA no later than the 25<sup>th</sup> day of the following month, unless otherwise specified by the permitting authority.

Permittees that have been granted a waiver shall mail Discharge Monitoring Reports with an original signature to the IEPA at the following address:

Illinois Environmental Protection Agency  
Division of Water Pollution Control  
Attention: Compliance Assurance Section, Mail Code # 19  
2520 West Iles Avenue  
Post Office Box 19276  
Springfield, Illinois 62794-9276

SPECIAL CONDITION 7. The provisions of 40 CFR Section 122.41(m) & (n) are incorporated herein by reference.

SPECIAL CONDITION 8. Samples taken in compliance with the effluent monitoring requirements shall be taken at a point representative of the discharge, but prior to entry into the receiving stream.

SPECIAL CONDITION 9. This Permit may be modified to include alternative or additional final effluent limitations pursuant to an approved Total Maximum Daily Load (TMDL) Study or upon completion of an alternate Water Quality Study.

SPECIAL CONDITION 10. For the duration of this Permit, the Permittee shall determine the quantity of sludge produced by the treatment facility in dry tons or gallons with average percent total solids analysis. The Permittee shall maintain adequate records of the quantities of sludge produced and have said records available for U.S. EPA and IEPA inspection. The Permittee shall submit to the IEPA, at a minimum, a semi-annual summary report of the quantities of sludge generated and disposed of, in units of dry tons or gallons (average total percent solids) by different disposal methods including but not limited to application on farmland, application on reclamation land, landfilling, public distribution, dedicated land disposal, sod farms, storage lagoons or any other specified disposal method. Said reports shall be submitted to the IEPA by January 31 and July 31 of each year reporting the preceding January thru June and July thru December interval of sludge disposal operations.

Duty to Mitigate. The Permittee shall take all reasonable steps to minimize any sludge use or disposal in violation of this Permit.

Sludge monitoring must be conducted according to test procedures approved under 40 CFR 136 unless otherwise specified in 40 CFR 503, unless other test procedures have been specified in this Permit.

Planned Changes. The Permittee shall give notice to the IEPA on the semi-annual report of any changes in sludge use and disposal.

The Permittee shall retain records of all sludge monitoring, and reports required by the Sludge Permit as referenced in Standard Condition 25 for a period of at least five (5) years from the date of this Permit.

If the Permittee monitors any pollutant more frequently than required by this permit or the Sludge Permit, the results of this monitoring shall be included in the reporting of data submitted to the IEPA.

The Permittee shall comply with existing federal regulations governing sewage sludge use or disposal and shall comply with all existing applicable regulations in any jurisdiction in which the sewage sludge is actually used or disposed.

The Permittee shall comply with standards for sewage sludge use or disposal established under section 405(d) of the CWA within the time provided in the regulations that establish the standards for sewage sludge use or disposal even if the permit has not been modified to incorporate the requirement.



NPDES Permit No. IL0045381

Special Conditions

The Permittee shall ensure that the applicable requirements in 40 CFR Part 503 are met when the sewage sludge is applied to the land, placed on a surface disposal site, or fired in a sewage sludge incinerator.

Monitoring reports for sludge shall be reported on the form titled "Sludge Management Reports" to the following address:

Illinois Environmental Protection Agency  
Bureau of Water  
Compliance Assurance Section  
Mail Code #19  
2520 West Iles Avenue  
Post Office Box 19276  
Springfield, Illinois 62794-9276

SPECIAL CONDITION 11. Mixing for ammonia was not granted for this discharge, since mixing is not necessary. Based on past DMR data, it appears that the facility can meet ammonia water quality standards in the effluent, without mixing. If mixing is determined to be needed, the permittee must demonstrate that the mixing zone requirements found at 35 Ill Adm. Code 302.102 (a) and (b) are met.



# ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

---

1021 NORTH GRAND AVENUE EAST, P.O. BOX 19276, SPRINGFIELD, ILLINOIS 62794-9276 • (217) 782-3397

**JB PRITZKER**, GOVERNOR

**JAMES JENNINGS**, ACTING DIRECTOR

2125 S. First Street, Champaign, IL 61820 (217) 278-5800  
115 S. LaSalle Street, Suite 2203, Chicago, IL 60603  
1101 Eastport Plaza Dr., Suite 100, Collinsville, IL 62234 (618) 346-5120  
9511 Harrison Street, Des Plaines, IL 60016 (847) 294-4000

595 S. State Street, Elgin, IL 60123 (847) 608-3131  
2309 W. Main Street, Suite 116, Marion, IL 62959 (618) 993-7200  
412 SW Washington Street, Suite D, Peoria, IL 61602 (309) 671-3022  
4302 N. Main Street, Rockford, IL 61103 (815) 987-7760

**PLEASE PRINT ON RECYCLED PAPER**