

NPDES Permit No. IL0079553  
Notice No. SAJ: 25042901.docx

Public Notice Beginning Date: July 7, 2025

Public Notice Ending Date: August 6, 2025

National Pollutant Discharge Elimination System (NPDES)  
Permit Program

Draft Reissued NPDES Permit to Discharge into Waters of the State

Public Notice/Fact Sheet Issued By:

Illinois Environmental Protection Agency  
Bureau of Water  
Division of Water Pollution Control  
Permit Section  
2520 West Iles Avenue  
Post Office Box 19276  
Springfield, Illinois 62794-9276  
217/782-0610

Name and Address of Discharger:

Huntsman International, LLC  
5015 Barnard Mill Road  
Ringwood, Illinois 60072

Name and Address of Facility:

Huntsman International, LLC  
5015 Barnard Mill Road  
Ringwood, Illinois 60072  
(McHenry County)

The Illinois Environmental Protection Agency (IEPA) has made a tentative determination to issue a NPDES permit to discharge into the waters of the state and has prepared a draft permit and associated fact sheet for the above named discharger. The Public Notice period will begin and end on the dates indicated in the heading of this Public Notice/Fact Sheet. The last day comments will be received will be on the Public Notice period ending date unless a commentor demonstrating the need for additional time requests an extension to this comment period and the request is granted by the IEPA. Interested persons are invited to submit written comments on the draft permit to the IEPA at the above address. Commentors shall provide his or her name and address and the nature of the issues proposed to be raised and the evidence proposed to be presented with regards to those issues. Commentors may include a request for public hearing. Persons submitting comments and/or requests for public hearing shall also send a copy of such comments or requests to the permit applicant. The NPDES permit and notice number(s) must appear on each comment page.

The application, engineer's review notes including load limit calculations, Public Notice/Fact Sheet, draft permit, comments received, and other documents are available for inspection and may be copied at the IEPA between 9:30 a.m. and 3:30 p.m. Monday through Friday when scheduled by the interested person.

If written comments or requests indicate a significant degree of public interest in the draft permit, the permitting authority may, at its discretion, hold a public hearing. Public notice will be given 45 days before any public hearing. Response to comments will be provided when the final permit is issued. For further information, please call Sadia A. Jame at 217/782-0610.

The applicant is engaged in the manufacturing and warehousing of thermoplastic polyurethane products (SIC 2821). Wastewater is generated from the discharge of non-contact wastewater, steam and air conditioning condensate, stormwater runoff, fire protection system test water, and miscellaneous wash waters. Plant operation results in an average discharge of 0.30 MGD of non-contact cooling water, steam and air conditioning condensate from outfall 003 and an intermittent discharge of stormwater runoff, fire protection system test water, and miscellaneous wash water from outfalls 004, 005, 006, and 007.

The non-contact cooling water and air conditioning system condensate wastewaters are routed from the Rohm and Haas Chemicals, LLC (IL0001716) to the Huntsman International, LLC and then routed back to Rohm and Haas Chemicals via aboveground and underground piping. Huntsman International is provided with steam by the Rohm and Haas Chemicals, LLC through a closed loop system and the majority of steam condensate is recycled by Rohm and Haas Chemicals, LLC. Huntsman International, LLC does not add any water additives to the non-contact cooling water, air conditioning system condensate, and steam. Application is made for existing discharges located in McHenry County, Illinois. The following information identifies the discharge point, receiving stream and stream classifications:

Outfall	Receiving Stream	Latitude		Longitude		Stream Classification	Integrity Rating
003	Dutch Creek	42° 23' 24"	North	88° 17' 48"	West	General Use	Not Rated
004	Dutch Creek	42° 23' 25"	North	88° 17' 51"	West	General Use	Not Rated
005	Dutch Creek	42° 23' 25"	North	88° 17' 49"	West	General Use	Not Rated
006	Dutch Creek	42° 23' 25"	North	88° 17' 48"	West	General Use	Not Rated
007	Dutch Creek	42° 23' 24"	North	88° 17' 48"	West	General Use	Not Rated

To assist you further in identifying the location of the discharges please see the attached map.


The subject facility discharges to Dutch Creek at a point where 0 cfs of flow exists upstream of the outfall during critical 7Q10 low-flow conditions. Dutch Creek classified as a General Use Water. Dutch Creek is not listed as a biologically significant stream in the 2008 Illinois Department of Natural Resources Publication Integrating Multiple Taxa in a Biological Stream Rating System, nor is it given an integrity rating in that document. Dutch Creek, Waterbody Segment IL\_DTN, is not listed on the 2024 Illinois Integrated Water Quality Report and Section 303(d) List since it has not been assessed. Dutch Creek is not subject to enhanced dissolved oxygen standards.

To address Per- and polyfluoroalkyl substances (PFAS) under the NPDES permit program the Illinois Environmental Protection Agency (IEPA), Bureau of Water, Permit Section has implemented a PFAS Reduction Initiative. Under this initiative, facilities with SIC codes that have been identified by USEPA as having the potential to use and/or discharge PFAS compounds are being required by IEPA to perform monitoring for PFAS compounds in their discharges and to implement Best Management Practices (BMP's) to reduce the potential for discharging PFAS to surface waters. The SIC code 2821 is on the USEPA list of SIC codes which indicates the need for both PFAS monitoring and the development and implementation of BMP's. Monitoring for PFAS has been added to the effluent limitations, monitoring, and reporting page(s) for Outfall 004, 005, 006 and 007 and Special Conditions 11 and 12 have been added to the permit as well.

The discharges from the facility shall be monitored and limited at all times as follows:

PARAMETER	LOAD LIMITS lbs/day		CONCENTRATION		REGULATION
	<u>DAF (DMF)</u>		<u>LIMITS mg/l</u>		
	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM	
<u>Outfall 003: Non-contact Cooling water, Steam, and Air Conditioning condensate</u>					
Flow (MGD)					35 IAC 309.146
pH				6.5-9	35 IAC 302.204
Temperature				Monitor Only	35 IAC 309.146
<u>Outfall 004, 005, 006 &amp; 007: Storm water Runoff (Intermittent Discharge)</u>					
Storm Water Pollution Prevention Plan					
					40 CFR 122.26(b)(14)(ii)
PFAS				Monitor Only	35 IAC 309.146

The following explain the conditions of the proposed permit: The special conditions clarify the following: flow monitoring and reporting, pH, temperature, monitoring location, DMR submissions, re-opener, stormwater discharge only, zinc, Storm Water Pollution Prevention Plan requirements, PFAS monitoring requirements, and PFAS best management practices (BMPs).



NPDES Permit No. IL0079553

Illinois Environmental Protection Agency

Division of Water Pollution Control

2520 West Iles Avenue

Post Office Box 19276

Springfield, Illinois 62794-9276

NATIONAL POLLUTANT DISCHARGE ELIMINATION SYSTEM

Reissued (NPDES) Permit

Expiration Date:

Issue Date:

Effective Date:

Name and Address of Permittee:

Huntsman International, LLC  
5015 Barnard Mill Road  
Ringwood, Illinois 60072

Facility Name and Address:

Huntsman International, LLC  
5015 Barnard Mill Road  
Ringwood, Illinois 60072  
(McHenry County)

Discharge Number and Name:

003 -Non-contact Cooling Water, Steam and Air  
Conditioning Condensate

004 -Stormwater Runoff, Fire Protection System Test Water,  
Equipment Wash Water, Water for External Building, Process  
Equipment and Miscellaneous Discharges.

005 -Stormwater Runoff, Fire Protection System Test Water,  
Equipment Wash Water, Water for External Building, Process  
Equipment and Miscellaneous Discharges.

006 -Stormwater Runoff, Fire Protection System Test Water,  
Equipment Wash Water, Water for External Building, Process  
Equipment and Miscellaneous Discharges.

007 -Stormwater Runoff, Fire Protection System Test Water,  
Equipment Wash Water, Water for External Building, Process  
Equipment and Miscellaneous Discharges.

Receiving Waters:

Dutch Creek through Rohm and Haas LLC Outfall  
001 (IL0001716)

Dutch Creek through Rohm and Haas LLC Outfall  
002 (IL0001716)

Dutch Creek through Rohm and Haas LLC Outfall  
002 (IL0001716)

Dutch Creek through Rohm and Haas LLC Outfall  
002 (IL0001716)

Dutch Creek through Rohm and Haas LLC Outfall  
002 (IL0001716)

In compliance with the provisions of the Illinois Environmental Protection Act, Title 35 of Ill. Adm. Code, Subtitle C and/or Subtitle D, Chapter 1, and the Clean Water Act (CWA), the above-named permittee is hereby authorized to discharge at the above location to the above-named receiving stream in accordance with the standard conditions and attachments herein.

Permittee is not authorized to discharge after the above expiration date. In order to receive authorization to discharge beyond the expiration date, the permittee shall submit the proper application as required by the Illinois Environmental Protection Agency (IEPA) not later than 180 days prior to the expiration date.

Stephen F. Nightingale, P.E.  
Manager, Industrial Unit, Permit Section  
Division of Water Pollution Control

NPDES Permit No. IL0079553

Effluent Limitations and Monitoring

1. From the effective date of this permit until the expiration date, the effluent of the following discharges shall be monitored and limited at all times as follows:

PARAMETER	LOAD LIMITS lbs/day <u>DAF (DMF)</u>		CONCENTRATION <u>LIMITS mg/l</u>		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM		
<u>Outfall 003</u> Non-contact Cooling Water, Steam and Air Conditioning Condensate (DAF = 0.30 GPD)						
Flow (MGD)	See Special Condition 1				Contiguous	Calculation
pH	See Special Condition 2				1/Month	Grab
Temperature	Monitor Only				1/Month	Single Reading

PARAMETER	LOAD LIMITS lbs/day <u>DAF (DMF)</u>		CONCENTRATION <u>LIMITS mg/l</u>		SAMPLE FREQUENCY	SAMPLE TYPE
	30 DAY AVERAGE	DAILY MAXIMUM	30 DAY AVERAGE	DAILY MAXIMUM		
<u>Outfall 004, 005, 006 &amp; 007</u> – Stormwater (Intermittent Discharge) *, Fire Protection System Test Water, Equipment Wash Water, Water for External Building, Process Equipment and Miscellaneous Discharges (DAF = 0.001 MGD, four times per year)						
Flow (MGD)	See Special Condition 1				Measure when discharging	Calculation
PFAS	Monitor Only				1/Quarter	**

\*See Special Condition 10

\*\*See Special Conditions 11 and 12

Special Conditions

SPECIAL CONDITION 1. Flow shall be measured in units of Million Gallons per Day (MGD) and reported as a monthly average and a daily maximum on the Discharge Monitoring Report. The monthly average shall consist of the summation of the daily flows divided by the number of days the facility discharged during that month.

SPECIAL CONDITION 2. The pH shall be in the range 6.5 to 9.0. The monthly minimum and monthly maximum values shall be reported on the DMR form.

SPECIAL CONDITION 3. The Permittee shall record monitoring results on Discharge Monitoring Report (DMR) electronic forms using one such form for the outfall each month.

In the event that an outfall does not discharge during a monthly reporting period, the DMR Form shall be submitted with no discharge indicated.

The Permittee is required to submit electronic DMRs (NetDMRs) instead of mailing paper DMRs to the IEPA unless a waiver has been granted by the Agency. More information, including registration information for the NetDMR program, can be obtained on the IEPA website, <https://epa.illinois.gov/topics/water-quality/surface-water/netdmr>.

The completed Discharge Monitoring Report forms shall be submitted to IEPA no later than the 25th day of the following month, unless otherwise specified by the permitting authority.

Permittees that have been granted a waiver shall mail Discharge Monitoring Reports with an original signature to the IEPA at the following address:

Illinois Environmental Protection Agency  
Division of Water Pollution Control  
Attention: Compliance Assurance Section, Mail Code # 19  
2520 West Iles Avenue  
Post Office Box 19276  
Springfield, Illinois 62794-9276

SPECIAL CONDITION 4. Samples taken in compliance with the effluent monitoring requirements shall be taken at a point representative of the discharge, but prior to entry into the receiving stream.

SPECIAL CONDITION 5. If an applicable effluent standard or limitation is promulgated under Sections 301(b)(2)(C) and (D), 304(b)(2), and 307(a)(2) of the Clean Water Act and that effluent standard or limitation is more stringent than any effluent limitation in the permit or controls a pollutant not limited in the NPDES Permit, the Agency shall revise or modify the permit in accordance with the more stringent standard or prohibition and shall so notify the permittee.

SPECIAL CONDITION 6. For the purpose of this permit, the discharge from Outfall 003 is limited to non-contact cooling water, steam, and air condensate, free from process and other wastewater discharges. In the event that the permittee shall request modification of this permit in accordance with attachment H prior to utilizing biosolids or bioremediated soils as final protective cover, final cover, intermediate cover or daily cover.

SPECIAL CONDITION 7. No effluent shall contain settleable solids, floating debris, visible oil, grease scum or sludge solids, color, odor and turbidity must be reduced to below obvious levels.

SPECIAL CONDITION 8. The permittee must notify Rohm and Haas Chemicals, LLC or the current holder of NPDES Permit IL0001716 prior to any modification to the discharge.

SPECIAL CONDITION 9. Monitoring and reporting of zinc will be required if the discharge from Rohm and Haas Chemical; LLC (IL0001716) causes any effluent or water quality violation for zinc when it exceeds limits of 1.0 mg/L and 2.0 mg/L. The Agency will modify this permit for the monitoring and reporting of zinc.

SPECIAL CONDITION 10.

STORM WATER POLLUTION PREVENTION PLAN (SWPPP)

A. A storm water pollution prevention plan shall be maintained by the permittee for the storm water associated with industrial activity at this facility. The plan shall identify potential sources of pollution which may be expected to affect the quality of storm water discharges associated with the industrial activity at the facility. In addition, the plan shall describe and ensure the implementation of practices which are to be used to reduce the pollutants in storm water discharges associated with industrial activity at the facility and to assure compliance with the terms and conditions of this permit. The permittee shall modify the plan if substantive changes are made or occur affecting compliance with this condition.

Special Conditions

1. Waters not classified as impaired pursuant to Section 303(d) of the Clean Water Act.

Unless otherwise specified by federal regulation, the storm water pollution prevention plan shall be designed for a storm event equal to or greater than a 25-year 24-hour rainfall event.

2. Waters classified as impaired pursuant to Section 303(d) of the Clean Water Act

For any site which discharges directly to an impaired water identified in the Agency's 303(d) listing, and if any parameter in the subject discharge has been identified as the cause of impairment, the storm water pollution prevention plan shall be designed for a storm event equal to or greater than a 25-year 24-hour rainfall event. If required by federal regulations, the storm water pollution prevention plan shall adhere to a more restrictive design criteria.

- B. The operator or owner of the facility shall make a copy of the plan available to the Agency at any reasonable time upon request. Facilities which discharge to a municipal separate storm sewer system shall also make a copy available to the operator of the municipal system at any reasonable time upon request.
- C. The permittee may be notified by the Agency at any time that the plan does not meet the requirements of this condition. After such notification, the permittee shall make changes to the plan and shall submit a written certification that the requested changes have been made. Unless otherwise provided, the permittee shall have 30 days after such notification to make the changes.
- D. The discharger shall amend the plan whenever there is a change in construction, operation, or maintenance which may affect the discharge of significant quantities of pollutants to the waters of the State or if a quarterly visual observation required by paragraph H or the annual facility inspection required by paragraph I of this condition indicates that an amendment is needed. The plan should also be amended if the discharger is in violation of any conditions of this permit, or has not achieved the general objective of controlling pollutants in storm water discharges. Amendments to the plan shall be made within 30 days of any proposed construction or operational changes at the facility, and shall be provided to the Agency for review upon request.
- E. The plan shall provide a description of potential sources which may be expected to add significant quantities of pollutants to storm water discharges, or which may result in non-storm water discharges from storm water outfalls at the facility. The plan shall include, at a minimum, the following items:
  1. A topographic map extending one-quarter mile beyond the property boundaries of the facility, showing: the facility, surface water bodies, wells (including injection wells), seepage pits, infiltration ponds, and the discharge points where the facility's storm water discharges to a municipal storm drain system or other water body. The requirements of this paragraph may be included on the site map if appropriate. Any map or portion of map may be withheld for security reasons.
  2. A site map showing:
    - i. The storm water conveyance and discharge structures;
    - ii. An outline of the storm water drainage areas for each storm water discharge point;
    - iii. Paved areas and buildings;
    - iv. Areas used for outdoor manufacturing, storage, or disposal of significant materials, including activities that generate significant quantities of dust or particulates.
    - v. Location of existing storm water structural control measures (dikes, coverings, detention facilities, etc.);
    - vi. Surface water locations and/or municipal storm drain locations
    - vii. Areas of existing and potential soil erosion;
    - viii. Vehicle service areas;
    - ix. Material loading, unloading, and access areas.
    - x. Areas under items iv and ix above may be withheld from the site for security reasons.
  3. A narrative description of the following:

Special Conditions

- i. The nature of the industrial activities conducted at the site, including a description of significant materials that are treated, stored or disposed of in a manner to allow exposure to storm water;
  - ii. Materials, equipment, and vehicle management practices employed to minimize contact of significant materials with storm water discharges;
  - iii. Existing structural and non-structural control measures to reduce pollutants in storm water discharges;
  - iv. Industrial storm water discharge treatment facilities;
  - v. Methods of onsite storage and disposal of significant materials.
4. A list of the types of pollutants that have a reasonable potential to be present in storm water discharges in significant quantities. Also provide a list of any pollutant that is listed as impaired in the most recent 303(d) report.
  5. An estimate of the size of the facility in acres or square feet, and the percent of the facility that has impervious areas such as pavement or buildings.
  6. A summary of existing sampling data describing pollutants in storm water discharges.
- F. The plan shall describe the storm water management controls which will be implemented by the facility. The appropriate controls shall reflect identified existing and potential sources of pollutants at the facility. The description of the storm water management controls shall include:
1. Storm Water Pollution Prevention Personnel - Identification by job titles of the individuals who are responsible for developing, implementing, and revising the plan.
  2. Preventive Maintenance - Procedures for inspection and maintenance of storm water conveyance system devices such as oil/water separators, catch basins, etc., and inspection and testing of plant equipment and systems that could fail and result in discharges of pollutants to storm water.
  3. Good Housekeeping - Good housekeeping requires the maintenance of clean, orderly facility areas that discharge storm water. Material handling areas shall be inspected and cleaned to reduce the potential for pollutants to enter the storm water conveyance system.
  4. Spill Prevention and Response - Identification of areas where significant materials can spill into or otherwise enter the storm water conveyance systems and their accompanying drainage points. Specific material handling procedures, storage requirements, spill cleanup equipment and procedures should be identified, as appropriate. Internal notification procedures for spills of significant materials should be established.
  5. Storm Water Management Practices - Storm water management practices are practices other than those which control the source of pollutants. They include measures such as installing oil and grit separators, diverting storm water into retention basins, etc. Based on assessment of the potential of various sources to contribute pollutants, measures to remove pollutants from storm water discharge shall be implemented. In developing the plan, the following management practices shall be considered:
    - i. Containment - Storage within berms or other secondary containment devices to prevent leaks and spills from entering storm water runoff. To the maximum extent practicable storm water discharged from any area where material handling equipment or activities, raw material, intermediate products, final products, waste materials, by-products, or industrial machinery are exposed to storm water should not enter vegetated areas or surface waters or infiltrate into the soil unless adequate treatment is provided.
    - ii. Oil & Grease Separation - Oil/water separators, booms, skimmers or other methods to minimize oil contaminated storm water discharges.
    - iii. Debris & Sediment Control - Screens, booms, sediment ponds or other methods to reduce debris and sediment in storm water discharges.
    - iv. Waste Chemical Disposal - Waste chemicals such as antifreeze, degreasers and used oils shall be recycled or disposed of in an approved manner and in a way which prevents them from entering storm water discharges.
    - v. Storm Water Diversion - Storm water diversion away from materials manufacturing, storage and other areas of potential storm water contamination. Minimize the quantity of storm water entering areas where material handling equipment of



Special Conditions

activities, raw material, intermediate products, final products, waste materials, by-products, or industrial machinery are exposed to storm water using green infrastructure techniques where practicable in the areas outside the exposure area, and otherwise divert storm water away from exposure area.

- vi. Covered Storage or Manufacturing Areas - Covered fueling operations, materials manufacturing and storage areas to prevent contact with storm water.
- vii. Storm Water Reduction - Install vegetation on roofs of buildings within adjacent to the exposure area to detain and evapotranspire runoff where precipitation falling on the roof is not exposed to contaminants, to minimize storm water runoff; capture storm water in devices that minimize the amount of storm water runoff and use this water as appropriate based on quality.
6. Sediment and Erosion Prevention - The plan shall identify areas which due to topography, activities, or other factors, have a high potential for significant soil erosion. The plan shall describe measures to limit erosion.
7. Employee Training - Employee training programs shall inform personnel at all levels of responsibility of the components and goals of the storm water pollution control plan. Training should address topics such as spill response, good housekeeping and material management practices. The plan shall identify periodic dates for such training.
8. Inspection Procedures - Qualified plant personnel shall be identified to inspect designated equipment and plant areas. A tracking or follow-up procedure shall be used to ensure appropriate response has been taken in response to an inspection. Inspections and maintenance activities shall be documented and recorded.
- G. Non-Storm Water Discharge - The plan shall include a certification that the discharge has been tested or evaluated for the presence of non-storm water discharge. The certification shall include a description of any test for the presence of non-storm water discharges, the methods used, the dates of the testing, and any onsite drainage points that were observed during the testing. Any facility that is unable to provide this certification must describe the procedure of any test conducted for the presence of non-storm water discharges, the test results, potential sources of non-storm water discharges to the storm sewer, and why adequate tests for such storm sewers were not feasible.
- H. Quarterly Visual Observation of Discharges - The requirements and procedures for quarterly visual observations are applicable to all outfalls covered by this condition.
  1. You must perform and document a quarterly visual observation of a storm water discharge associated with industrial activity from each outfall. The visual observation must be made during daylight hours. If no storm event resulted in runoff during daylight hours from the facility during a monitoring quarter, you are excused from the visual observations requirement for that quarter, provided you document in your records that no runoff occurred. You must sign and certify the document.
  2. Your visual observation must be made on samples collected as soon as practical, but not to exceed 1 hour or when the runoff or snow melt begins discharging from your facility. All samples must be collected from a storm event discharge that is greater than 0.1 inch in magnitude and that occurs at least 72 hours from the previously measureable (greater than 0.1 inch rainfall) storm event. The observation must document: color, odor, clarity, floating solids, settled solids, suspended solids, foam, oil sheen, and other obvious indicators of storm water pollution. If visual observations indicate any unnatural color, odor, turbidity, floatable material, oil sheen or other indicators of storm water pollution, the permittee shall obtain a sample and monitor for the parameter or the list of pollutants in Part E.4.
  3. You must maintain your visual observation reports onsite with the SWPPP. The report must include the observation date and time, inspection personnel, nature of the discharge (i.e., runoff or snow melt), visual quality of the storm water discharge (including observations of color, odor, floating solids, settled solids, suspended solids, foam, oil sheen, and other obvious indicators of storm water pollution), and probable sources of any observed storm water contamination.
  4. You may exercise a waiver of the visual observation requirement at a facility that is inactive or unstaffed, as long as there are no industrial materials or activities exposed to storm water. If you exercise this waiver, you must maintain a certification with your SWPPP stating that the site is inactive and unstaffed, and that there are no industrial materials or activities exposed to storm water.
  5. Representative Outfalls - If your facility has two or more outfalls that you believe discharge substantially identical effluents, based on similarities of the industrial activities, significant materials, size of drainage areas, and storm water management practices occurring within the drainage areas of the outfalls, you may conduct visual observations of the discharge at just one of the outfalls and report that the results also apply to the substantially identical outfall(s).
  6. The visual observation documentation shall be made available to the Agency and general public upon written request.

Special Conditions

- I. The permittee shall conduct an annual facility inspection to verify that all elements of the plan, including the site map, potential pollutant sources, and structural and non-structural controls to reduce pollutants in industrial storm water discharges are accurate. Observations that require a response and the appropriate response to the observation shall be retained as part of the plan. Records documenting significant observations made during the site inspection shall be submitted to the Agency in accordance with the reporting requirements of this permit.
- J. This plan should briefly describe the appropriate elements of other program requirements, including Spill Prevention Control and Countermeasures (SPCC) plans required under Section 311 of the CWA and the regulations promulgated there under, and Best Management Programs under 40 CFR 125.100.
- K. The plan is considered a report that shall be available to the public at any reasonable time upon request.
- L. The plan shall include the signature and title of the person responsible for preparation of the plan and include the date of initial preparation and each amendment thereto.
- M. Facilities which discharge storm water associated with industrial activity to municipal separate storm sewers may also be subject to additional requirement imposed by the operator of the municipal system

Construction Authorization

Authorization is hereby granted to construct treatment works and related equipment that may be required by the Storm Water Pollution Prevention Plan developed pursuant to this permit.

This Authorization is issued subject to the following condition(s).

- N. If any statement or representation is found to be incorrect, this authorization may be revoked and the permittee there upon waives all rights there under.
- O. The issuance of this authorization (a) does not release the permittee from any liability for damage to persons or property caused by or resulting from the installation, maintenance or operation of the proposed facilities; (b) does not take into consideration the structural stability of any units or part of this project; and (c) does not release the permittee from compliance with other applicable statutes of the State of Illinois, or other applicable local law, regulations or ordinances.
- P. Plans and specifications of all treatment equipment being included as part of the stormwater management practice shall be included in the SWPPP.
- Q. Construction activities which result from treatment equipment installation, including clearing, grading and excavation activities which result in the disturbance of one acre or more of land area, are not covered by this authorization. The permittee shall contact the IEPA regarding the required permit(s).

REPORTING

- R. The annual inspection report shall include results of the annual facility inspection which is required by Part I of this condition. The report shall also include documentation of any event (spill, treatment unit malfunction, etc.) which would require an inspection, results of the inspection, and any subsequent corrective maintenance activity. The report shall be completed and signed by the authorized facility employee(s) who conducted the inspection(s). The annual inspection report is considered a public document that shall be available at any reasonable time upon request.
- S. The first report shall contain information gathered during the one year time period beginning with the effective date of coverage under this permit and shall be submitted no later than 60 days after this one year period has expired. Each subsequent report shall contain the previous year's information and shall be submitted no later than one year after the previous year's report was due.
- T. If the facility performs inspections more frequently than required by this permit, the results shall be included as additional information in the annual report.
- U. The permittee shall retain the annual inspection report on file at least 3 years. This period may be extended by request of the Illinois Environmental Protection Agency at any time.

Annual inspection reports shall be submitted electronically at [epa.npdes.inspection@illinois.gov](mailto:epa.npdes.inspection@illinois.gov) or mailed to the following address:

Illinois Environmental Protection Agency  
Bureau of Water

Special Conditions

Compliance Assurance Section  
Annual Inspection Report  
2520 W Iles Avenue  
Post Office Box 19276  
Springfield, Illinois 62794-9276

V. The permittee shall notify any regulated small municipal separate storm sewer owner (MS4 Community) that they maintain coverage under an individual NPDES permit. The permittee shall submit any SWPPP or any annual inspection to the MS4 community upon request by the MS4 community.

SPECIAL CONDITION 11.

## 1) PFAS Sample Frequency and Type of Sample.

<u>Sampling Point</u>	<u>Sample Frequency</u>	<u>Sample Type</u>	<u>Report</u>
Effluent	Quarterly*	Grab	ng/L

\*Quarterly sampling – Testing done during the first quarter (January – March) must be reported on the April Electronic Discharge Monitoring Report (NetDMR), testing done in the second quarter (April – June) must be reported on the July NetDMR, testing done in the third quarter (July – September) must be reported on the October NetDMR, and testing done in the fourth quarter (October – December) must be reported on the January NetDMR. In the event that an outfall does not discharge during a quarterly reporting period, the NetDMR Form shall be submitted with no discharge indicated.

- 2) Test results must be reported in nanograms per liter (ng/L) as a daily maximum concentration.
- 3) Monitoring for Per- and polyfluoroalkyl Substances (PFAS) shall be performed using USEPA 3<sup>rd</sup> draft test method 1633 or subsequent draft test method. Upon USEPA's final approval and incorporation under 40 CFR 136, the approved method shall be used for PFAS testing.
- 4) The Minimum Level (ML) of Detection identified in paragraph 6) of this Special Condition is based on the USEPA's 3<sup>rd</sup> Draft Method 1633, dated December 2022. The permittee shall use these minimum levels of detection until they are replaced by subsequent draft methods, or a final method is defined under 40 CFR 136. At that time of update the permittee shall use the revised minimum level of detection values as part of this permit.
- 5) Following two years of quarterly sampling, the permittee may request a reduction in testing frequency, or an elimination of testing, by filing an NPDES permit modification request with the Agency. Quarterly sampling shall continue until such time as the Agency modifies the NPDES permit to either reduce or eliminate the quarterly sampling requirement.
- 6) Specific PFAS constituents that must be analyzed for are listed in the following table:

Target Analyte Name	Abbreviation	CAS Number	STORET	Minimum Level (ML) of Detection	
Perfluoroalkyl carboxylic acids				Aqueous (ng/L)	Solids (ng/g)
Perfluorobutanoic acid	PFBA	375-22-4	51522	2.0	0.8
Perfluoropentanoic acid	PFPeA	2706-90-3	51623	2.0	0.4
Perfluorohexanoic acid	PFHxA	307-24-4	51624	2.0	0.2
Perfluoroheptanoic acid	PFHpA	375-85-9	51625	2.0	0.2
Perfluorooctanoic acid	PFOA	335-67-1	51521	2.0	0.2
Perfluorononanoic acid	PFNA	375-95-1	51626	2.0	0.2
Perfluorodecanoic acid	PFDA	335-76-2	51627	2.0	0.2
Perfluoroundecanoic acid	PFUnA	2058-94-8	51628	2.0	0.2
Perfluorododecanoic acid	PFDoA	307-55-1	51629	2.0	0.2

Special Conditions

Perfluorotridecanoic acid	PFTTrDA	72629-94-8	51630	2.0	0.2
Perfluorotetradecanoic acid	PFTTeDA	376-06-7	51631	2.0	0.2
<b>Perfluoroalkyl sulfonic acids</b>					
<b>Acid Forms</b>					
Perfluorobutanesulfonic acid	PFBS	375-73-5	52602	2.0	0.2
Perfluoropentanesulfonic acid	PFPeS	2706-91-4	52610	2.0	0.2
Perfluorohexanesulfonic acid	PFHxS	355-46-4	52605	2.0	0.2
Perfluoroheptanesulfonic acid	PFHpS	375-92-8	52604	2.0	0.2
Perfluorooctanesulfonic acid	PFOS	1763-23-1	52606	2.0	0.2
Perfluorononanesulfonic acid	PFNS	68259-12-1	52611	2.0	0.2
Perfluorodecanesulfonic acid	PFDS	335-77-3	52603	2.0	0.2
Perfluorododecanesulfonic acid	PFDoS	79780-39-5	52632	2.0	0.2
<b>Fluorotelomer sulfonic acids</b>					
1H,1H, 2H, 2H-Perfluorohexane sulfonic acid	4:2FTS	757124-72-4	52605	5.0	0.8
1H,1H, 2H, 2H-Perfluorooctane sulfonic acid	6:2FTS	27619-97-2	62606	10	0.8
1H,1H, 2H, 2H-Perfluorodecane sulfonic acid	8:2FTS	39108-34-4	52603	10	0.8
<b>Perfluorooctane sulfonamides</b>					
Perfluorooctanesulfonamide	PFOSA	754-91-6	51525	2.0	0.2
N-methyl perfluorooctanesulfonamide	NMeFOSA	31506-32-8	52641	2.0	0.2
N-ethyl perfluorooctanesulfonamide	NEtFOSA	4151-50-2	52642	2.0	0.2
<b>Perfluorooctane sulfonamidoacetic acids</b>					
N-methyl perfluorooctanesulfonamidoacetic acid	NMeFOSAA	2355-31-9	51644	2.0	0.2
N-ethyl perfluorooctanesulfonamidoacetic acid	NEtFOSAA	2991-50-6	51643	2.0	0.2
<b>Perfluorooctane sulfonamide ethanols</b>					
N-methyl perfluorooctanesulfonamidoethanol	NMeFOSE	24448-09-7	51642	10	2
N-ethyl perfluorooctanesulfonamidoethanol	NEtFOSE	1691-99-2	51641	20	2
<b>Per- and Polyfluoroether carboxylic acids</b>					
Hexafluoropropylene oxide dimer acid	HFPO-DA	13252-13-6	52612	5.0	0.8
4,8-Dioxa-3H-perfluorononanoic acid	ADONA	919005-14-4	52636	5.0	0.8
Perfluoro-3-methoxypropanoic acid	PFMPA	377-73-1	PF002	2.0	0.4
Perfluoro-4-methoxybutanoic acid	PFMBA	863090-89-5	PF006	2.0	0.4
Nonafluoro-3,6-dioxaheptanoic acid	NFDHA	151772-58-6	52626	5.0	0.4
<b>Ether sulfonic acids</b>					
9-Chlorohexadecafluoro-3-oxanonane-1-sulfonic acid	9Cl-PF3ONS	756426-58-1	PF003	5.0	0.8
11-Chloroeicosafluoro-3-oxaundecane-1-sulfonic acid	11Cl-PF3OUdS	763051-92-9	PF004	5.0	0.8
Perfluoro(2-ethoxyethane)sulfonic acid	PFEESA	113507-82-7	52629	2.0	0.4
<b>Fluorotelomer carboxylic acids</b>					
3-Perfluoropropyl propanoic acid	3:3FTCA	356-02-5	PF001	10	1.0
2H,2H,3H,3H-Perfluorooctanoic acid	5:3FTCA	914637-49-3	PF007	20	5.0
3-Perfluoroheptyl propanoic acid	7:3FTCA	812-70-4	PF005	20	5.0

Special Conditions

SPECIAL CONDITION 12. PFAS Minimization Program

1) PFAS Reduction Initiative:

- a) Within 6 months from the effective date of the permit the Permittee shall develop and implement a PFAS reduction initiative. The reduction initiative must include Best Management Practices (BMP's).
- b) Best Management Practices (BMPs) must include an evaluation based on product substitution, reduction, or elimination of PFAS in discharges as detected by method 1633. When developing a BMP, the following should be considered, at a minimum:
  - i) Evaluation of the potential for the industrial facility to use products containing PFAS or have knowledge or suspect wastewater being discharged under the NPDES permit to contain PFAS.
  - ii) Evaluation of Pollution prevention/source reduction opportunities which may include:
    - (1) Product elimination or substitution when a reasonable alternative to using PFAS is available in the industrial process,
    - (2) Accidental discharge minimization by optimizing operations and good housekeeping practices,
    - (3) Equipment decontamination or replacement (such as in metal finishing facilities) where PFAS products have historically been used to prevent discharge of legacy PFAS following the implementation of product substitution.
  - iii) Identification of the measures being taken to reduce PFAS loading from the facility, and any available information, including facility wastewater testing for PFAS, and/or the loading reduction achieved.
- c) BMP's for PFAS must be reevaluated in accordance with paragraph 1 b) of this Special Condition and updated on an annual basis. The reevaluated BMP's must include any updates made since the previous BMP was submitted.
- d) The Permittee is required to submit a PFAS reduction report annually to the Illinois Environmental Protection Agency at the address indicated under paragraph 2) of this Special Condition, with the first report due 12 months from the permit effective date. Subsequent annual reports shall be due 12 months following the previous report's due date.

PFAS reduction reports must include the following information:

- i) The name, address, and NPDES permit number of the Permittee,
  - ii) The current BMP for the facility. Reevaluated BMP's must also include all updates made since the previous BMP was submitted.
- 2) The Permittee shall submit the PFAS reduction reports identified under paragraphs 1) of this Special Condition electronically or in writing to the one of the following addresses:
- a) [EPA.PrmtSpecCondtns@Illinois.gov](mailto:EPA.PrmtSpecCondtns@Illinois.gov), or
  - b) Illinois Environmental Protection Agency  
Bureau of Water  
Compliance Assurance Section  
Mail Code #19  
2520 West Iles Avenue  
Post Office Box 19276  
Springfield, Illinois 62794-9276

Special Conditions